EMERGENCY LIGHTING AND EXIT SIGN TESTING

Standard Fire Prevention Code 1999

807.1.4 Exit Illumination and Signs A functional test shall be conducted on every required emergency lighting system at 30-day intervals for a minimum of 30-seconds.

NFPA 101 - Life Safety Code

- Requires a monthly inspection of all emergency and exit lighting systems
- Requires an annual test of all emergency and exit lighing systems

YEAR 20

MONTH	EXIT SIGN #1		EXIT SIGN #2		EXIT SIGN #3		EXIT SIGN #4		EXIT SIGN #5	
	SIGN	LIGHTS								
JANUARY										
FEBRUARY										
MARCH										
APRIL										
MAY										
JUNE										
JULY										
AUGUST										
SEPTEMBER										
OCTOBER										
NOVEMBER										
DECEMBER										

CHECK MARK EACH BOX ACCORDING TO THE TEST RESULTS, NOTIFY MAINTENANCE TEAM IF NOT WORKING.